

ELECTRICAL LOAD CALCULATION

Project Number: 2016.007
 Coffey County Housing Authority
 Tri-plex Model #2016-01



DATE: May 5, 2016

Lighting Load:				
Lighting Load:	1904 SQ. FT.	X	3 va =	5712 va
Small Appliance Circuits	3 #Of	X	1500 va =	4500 va
Laundry Circuit:	1 #Of	X	1500 va =	1500 va
			Subtotal	11712 va
Table 220-11 Lighting Demand				
First 3000 va @ 100%				3000 va
30,001 to 120,000 @ 35%	8712 va	X	0.35	3049
Remaining va @ 25%	0 va	X	0.25 =	0 va
Total Lighting Load				6049 va
Electric Heat (per NEC. ART. 424-3 (b) at 125%)				
Kw	0 *K/240	=	0 Amps	
Electric Heat (@125%)	0 Amps	X	240 volts =	0 va
Furnace Blower (@ 125%)	12 Amps	X	120 volts =	1800 va
Electric Heat + Furnace Blower				1800 va
AC or Heat Pump + Furnace Blower	18 Amps	X	240 volts =	6120 va
(Compare electric heat against A/C load. Omit the smaller.)				
Heating Cooling Load				6120 va
Noncontinuous Loads				
Range or Cooktop 10.3 Kw Derated				8400 va
Water Heater	0 Amps	X	240 volts =	0 va
Clothes Dryer (Min 5000 W)	12.5 Amps	X	240 volts =	5000 va
Others Noncontinuous Loads	0 Amps	X	240 volts=	0 va
	Amps	X	240 volts=	0 va
Total Noncontinuous Loads				13400
Motor Loads				
Dishwasher	10.4 Amps	X	120 volts =	1248 va
Garbage Disposal	6.5 Amps	X	120 volts =	780 va
Other Motor Loads	Amps	X	240 volts =	0 va
	Amps	X	240 volts =	0 va
220-14 Largest motor in F.L.C. increased 25%				3 va
Total Motor Load				2031 va
Continuous Loads				
	Amps	X	240 volts =	0 va
	Amps	X	240 volts =	0 va
	Amps	X	240 volts =	0 va
220-10(b) increased Continuous Loads to 125%				0 va
Total Continuous Loads	TOTAL			0 va
TOTAL AMPS = Total va	115 Amps	X	240 volts =	27600 va